

LAB#	101034-101039
------	---------------

BRANDYWINE SCIENCE CENTER INC.
 204 LINE ROAD
 KENNETT SQUARE, PA 19348
 DEP # 15-301
 (610) 444-9850
 (610) 444-4080 FAX



ORIGIN OF SAMPLE	NAME	Cooperative Nursery School			
	ADDRESS				
	CITY/STATE				
SOURCE OF SUPPLY	CITY	x	MANNER OF COLLECTION	COUNTY	
	SPRING			INSIDE TAP	see below
	TREATED			OUTSIDE TAP	
SAMPLE COLLECTED BY	LAB STAFF		SAMPLE INFORMATION	OTHER	
	WELL DRILLER			SAMPLE DATE	1/29/21
	OTHER	Jess Stanforth		SAMPLE TIME	10:00
TRANSPORT INFORMATION	ICE /REFRIG	x		DATE RECEIVED	1/29/21
				TIME RECEIVED	11:30
				DATE OF REPORT	2/10/21

CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE/TIME ANALYST	METHOD
lab# 101034 sample location: kitchen	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B
lab# 101035 sample location: handwash - L	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B
lab# 101036 sample location: handwash - R	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B
lab# 101037 sample location: utility	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B
lab# 101038 sample location: bathroom - L	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B
lab# 101039 sample location: bathroom - R	LEAD	<0.005	0.015	mg/L	2/5/21 17:57 HC SM 3113 B

Total Coliform performed by the SM 9223 "Colilert" method, Nitrate is performed by SM 4500NO3D Nitrite is performed by SM4500NO2D
 Chemical analyses performed in accordance with "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTEWATER", 18th EDITION APHA-AWWA-WPCF.

Henry D. Clemens III

Henry D. Clemens III
 Laboratory Director